Inspector's Daily Report

Litchfield, ME Town of Litchfield, ME Public Works

Contract: Lunts Hill Road IDR Date Day of Week Project Engineer Project Inspector Seq. No. 8/22/2022 Litchfield Jeremy Pollis Monday 1 **Inspector's Initials Project Number** Attachments JP Lunts Hill Road None **Prime Contractor** All States Materials Group **Entered By Daily Operations** JP Start: 7:00 AM End: 4:30 PM **Temperatures** Weather (AM) Weather (PM) Cloudy Overcast Low: 64 ^o F High: 80^o F Contractors Daily Hours of Operation: 7:00 AM - 4:30 PM **Operations:** All States Materials was on site to re-mill the previously milled Lunt's Hill Road surface and add water. All States milled/scarified approximately 4" into the reclaimed surface and added water via water truck. The surface was recompacted and regraded after the milling and watering. Compaction appeared adequate- no yielding of the gravel was observed. This process was completed on approximately 18,333 SY of road (7,500' X 22'). **Traffic Control:** No issues were observed with maintenance of traffic. Adequate signs, cones and flaggers used for today's operations. Flaggers: (2) & 1 Breaker **Erosion & Sedimentation Control:** N/A **Project Construction Notes:** Will continue work on Monday 8/22 starting with injection of liquid asphalt. Work inspected by Jeremy Pollis 8.22.22

| | Contractors | | |
|-------------|--|----------------------|---|
| All States | <mark>Personnel</mark> Foreman Laborer | <u>No.</u> 1 0 | <u>Equipment</u> <u>No.</u> Pickup 1 CatRM 500 Mill 1 |
| | Laborer | Ŭ | Cat roller 1 Svc Truck 1 Asphalt Truck 1 Water Truck 1 |
| | Operator | 3 | |
| | Superintendent | 1 | |
| | Truck Driver | | |
| Gleinfelder | Personnel Inspector's | <u>No.</u> 1 | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |
| | | | |



